Printed Pages-7

EEE501

(Following Paper ID and	d Roll No	. to	be f	illed	d in	yo	ur A	nsv	ver	Bo	ok)
PAPER ID: 2111 R	oll No.	100		2-120	in i	ter)	er Ergs				

B.Tech.

(SEM. V) THEORY EXAMINATION 2011-12 ELECTROMECHANICAL ENERGY CONVERSION-II

Time : 3 Hours

Total Marks : 100

Note :---All questions carry equal marks.

- 1. Answer any four parts of the following : (5×4=20)
 - (a) Explain why $3-\phi$ synchronous machines are always run at

synchronous speed $\left(N_s = \frac{120 \text{ f}}{P}\right)$? The symbols having their usual meanings.

- (b) Explain why 3-φ synchronous machines are not self starting
 ? What are the methods for starting of the 3φ synchronous machines ?
- (c) Define the v-curves and inverted v-curves at different loading conditions of synchronous motors.
- (d) Discuss the constructional details and working principles of 3φ synchronous machines. Also mention its applications.
- (e) Explain why in case of 3ϕ synchronous machines, the armature windings put on stator and field windings put on

EEE501/KIH-26183

[Turn Over

rotor whereas in case of D.C. machines, the armature windings put on rotor and field windings put on stator poles? Explain in brief.

- (f) Write short notes on any two of the following :
 - (i) Mode of operations of synchronous motors.
 - (ii) Hunting Phenomena in 3 ϕ Synchronous motors.
 - (iii) Power Flow Equations of Cylindrical and Salient Pole Machines.
- 2. Answer any two parts of the following: (10×2=20)
 (a) For a cylindrical rotor alternator working at lagging power factor, show that

$$\tan \delta = \frac{I_a (X_s \cos \theta - r_a \sin \theta)}{V_t + I_a (X_s \sin \theta + r_a \cos \theta)}$$

The symbols having their usual meanings.

- (b) A 5 MVA, 11 kV, 50 Hz, 4-pole, star-connected synchronous generator with synchronous reactance of 0.7 p.u. is connected to an infinite bus. Find synchronizing power and the corresponding torque per unit of mechanical angle displacement —
 - (i) at no load and
 - (ii) at full load of 0.8. p.f. lagging.

EEE501/KIH-26183

(c) A 500 KVA, 11KV, 3-φ, star-connected alternators has the following data:

Friction and windage loss	1 (C) (C)	1500 W
Open-circuit core loss	<u>_</u> (2500 W
Effective armature resistance/phase	=	40 Ω
Field copper loss	=	1000 W
	1000	

Find the following parts in regarding with above synchronous alternators :

- (i) Alternator efficiency of half-full load and at 0.85 power factor lagging.
- (ii) Maximum efficiency of the alternator.
- 3. Answer any two parts of the following : $(10 \times 2 = 20)$
 - (a) What are the similarities and dissimilarities between "Three Phase Transformers" and "Three Phase Induction Machines" ? Explain why a 3-φ IM can't runs at

synchronous speed $\left(N_s = \frac{120 \text{ f}}{P}\right)$, symbols having their usual meanings ? Also explain the phenomena such as "Cogging" and "Crawling" associated with a 3 ϕ IM.

EEE501/KIH-26183

3

[Turn Over

(b) A 3 φ squirrel cage IM (SCIM) has maximum torque equal to twice the full-load torque. Determine the ratio of motor torque to its full load torque, if it is started by :

(i) D.O.L. Starter

(ii) Auto-transformer starter with 70% tapping.

(iii) Star-delta Starter.

The per phase rotor resistance and per phase standstill reactance referred to stator are 0.2 Ω and 2 Ω respectively. Neglect stator impedance.

(c) A 10 kW, 400 V, 50 Hz, 4-pole, Y-connected squirrel cage.IM gave the following test results :

No-load Test 400 V		8A	250 Watts			
Blocked rotor Test	90 V	35A	1350 watts.			

The d.c. resistance of the stator winding per phase measured immediately after the blocked rotor test is 0.6Ω .


Calculate the following :

(i) Equivalent circuit parameters of 3ϕ SCIM.

(ii) Rotational losses.

EEE501/KIH-26183

- 4. Answer any two parts of the following: $(10 \times 2=20)$
 - (a) What are the methods for speed control of squirrel cage IM and wound type IM ? Also mention its advantages and disadvantages. Discuss the field of applications of speed control methods of IMs.
 - (b) Consider the equivalent circuit diagram of 3φ, Y-connected,
 440 V, 50 Hz, 4-pole, IM shown in Fig.1 :



where $r_1 = 0.294 \ \Omega$; $x_1 = 0.503 \ \Omega$; $X_m = 13.25 \ \Omega$; $r_2 = 0.209 \ \Omega$; $x_2 = 0.144 \ \Omega$.

Fig.1. Equivalent circuit diagram of IM.

- (i) Determine the stator current and power factor (motor runs at N = 1460 RPM)
- (ii) Determine the air gap power and rotor copper losses (motor runs at $N_r = 1450$ RPM).
- (iii) What is the value of motor speed at which it takes 30 Ampere current at 0.8 p.f. lagging from supply mains?
- (iv) What is the value of slip when motor runs at

N_= 1480 RPM ?

EEE501/KIH-26183

[Turn Over

(c) The impedances at standstill of the inner and outer cages of a double cage rotor are (0.01 + J 0.5) Ω and . (0.05 + j 0.1) Ω respectively. The stator impedance may be assumed to be negligible.

Calculate the ratio of the torques due to the two cages-

- (i) at starting, and
- (ii) when running with a slip of 5%.

5. Answer any two parts of the following : $(10 \times 2 = 20)$

- (a) Explain why 1-φ IMs are not self starting ? What do you understand by "FORWARD FIELD" and "BACKWARD FIELD" in conjunction with 1-φ IM ? Draw and explain the equivalent circuit diagram of 1-φ IM at no-load and blocked rotor tests. Also explain the double resolving field theory associated with 1-φ IM. What are the methods of starting of 1-φ IM ? Explain the working principle of 1-φ shaded pole type IM and its domestic applications.
- (b) Explain the constructional details and working principle of 1-φ reluctance motors. Also mention its domestic applications. What are the advantages and disadvantages of this motors ? Compare their performance from 1-φ hysteresis motors.

EEE501/KIH-26183

20

(c) Discuss the constructional details and working principle of any two of the following :

- (i) Stepper Motors
- (ii) Universal Motor
- (iii) Single phase AC series compensated motors.

Beneric and reaction to the Party services.

(b) Dig. also is a matrix summaries and a second density 2. When the state of the state of the second seco second sec

and the second second

8775

Also mention their industrial applications.

Estas en Bancoul

colabartaj

EEE501/KIH-26183